

Food Safety Drug Administration Department of Uttar Pradesh
GOVERNMENT/REGIONAL PUBLIC ANALYST LABORATORY

Address:- Regional Public Analyst Laboratory, Medical College Campus, Jhansi. 284128
Email:- fsdalabjhansi@gmail.com



Test Report

(For Samples under Aam Jan Manas Scheme)

Report No:- JHS- 5621

Report Date:- 10.03-2026

Issued to:- Seth Anandram Jaipuria School, Janta Road, Saharanpur (U.P.)

Sample Collected/Submitted by:- Principal for Seth Anandram Jaipuria School, Janta Road, Saharanpur (U.P.)

Sample Description:- Transparent liquid sample is in ordinary plastic bottle.

Nature of sample:- Drinking Water.

Test Results

Sr. no.	Test Parameter	Result	Specification	Test Method
1	pH	7.10	6.5-8.5	FSSAI Manual
2	Taste	Agreeable	Agreeable	FSSAI Manual
3	Odour	Agreeable	Agreeable	FSSAI Manual
4	Turbidity	Non-Turbid	Not more than 2 nephelo metric turbidity unit (NTU)	FSSAI Manual
5	Total dissolved solids (T.D.S.)	179.2 mg/l	Not more than 500 mg/l	FSSAI Manual
6	Chloride (as Cl)	151.3 mg/l	Not more than 200 mg/l	FSSAI Manual
7	Sulphates (as So ₄)	121.8 mg/l	Not more than 200 mg/l	FSSAI Manual
8	Test for Mineral oil	Negative	Should be Negative	FSSAI Manual

Opinion:- On the basis of tests performed, no adulterant is detected.

Place:- Regional Public Analyst Laboratory, Medical College Campus, Jhansi.

Date:- 10-03-2026

Authorised signatory

Vipin Kumar Shukla
Food Analyst U.P
JHANSI

Note:-

1. Samples will be destroyed after one month in case of non perishable and 10 days in case of perishables.
2. Test report will not be reproduced, without written approval from laboratory and shall not be used for advertising/ publicity in full or in part.
3. The test report not be used for any legal action relating to FSS Act 2006 and its rules and regulation.

Seth Anandram Jaipuria School

Auth. Sign.

President/Secretary

Principal

Seth Anandram Jaipuria School
Janta Road, Saharanpur (U.P.)